

# 深圳妈湾电力有限公司2016年8月#1机组烟气数据



浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#1机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	11	10	2043	5.3	81	99.0	2.3	3.2	34	32
2	4	5	1954	6.8	79	99.3	2.7	4.2	22	24
3	14	14	2096	5.9	78	98.1	2.0	3.0	26	25
4	6	6	2241	5.9	77	99.0	1.9	2.8	22	21
5	9	9	2374	5.9	79	98.7	2.0	2.9	26	26
6	17	16	2286	4.9	82	97.8	2.0	2.7	38	35
7	21	19	2162	4.7	83	97.5	1.9	2.5	42	39
8	23	21	2152	4.8	83	97.4	1.9	2.6	40	37
9	10	9	2143	5.4	78	98.7	2.2	3.1	28	27
10	7	7	2087	6.3	75	99.1	2.5	3.7	25	25
11	15	15	2124	5.8	78	98.2	2.4	3.5	30	29
12	21	21	2077	6.0	79	98.0	2.3	3.4	27	27
13	14	13	2088	5.8	80	98.5	2.3	3.4	28	27
14	6	6	2035	6.0	79	99.4	2.3	3.4	23	23
15	15	15	1918	6.0	79	98.6	2.3	3.4	24	24
16	11	12	1844	6.6	79	98.6	2.2	3.3	28	29
17	8月16日22:57机组停运, 8月22日5:11机组启动运行									
18										
19										
20										
21										
22										
23	5	5	2019	5.3	81	99.4	2.1	2.9	31	29
24	5	5	2059	5.4	81	99.4	2.0	2.9	33	31
25	7	6	2177	4.9	82	99.3	2.2	3.1	38	35
26	8	7	2101	5.3	80	99.1	2.4	3.3	31	29
27	5	5	2016	5.6	78	99.5	2.5	3.6	26	25
28	3	3	1892	6.6	76	99.7	2.8	4.3	25	26
29	3	3	1815	7.4	78	99.7	2.6	4.2	29	33
30	9	8	1978	5.8	79	99.2	1.4	2.0	31	30
31	7	6	2088	5.4	79	99.3	1.2	1.7	33	32
最大值	23	21	2374	7.4	83	99.7	2.8	4.3	42	39
最小值	3	3	1815	4.7	75	97.4	1.2	1.7	22	21
平均	10	10	2071	5.7	79	98.8	2.2	3.2	29	29

制表人: 李中坚

审核人: 吴兴远

企业负责人: 卢连成

# 深圳妈湾电力有限公司2016年8月#2机组烟气数据



浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#2机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	13	12	2090	5.2	82	98.8	2.3	3.2	29	28
2	7	7	1994	6.4	81	99.2	2.7	4.2	21	22
3	9	8	2254	5.7	80	99.0	2.0	3.0	26	26
4	7	7	2542	5.9	76	99.2	1.9	2.8	28	28
5	17	17	2611	5.6	80	98.0	2.0	2.9	28	27
6	21	19	2883	4.8	84	97.6	2.0	2.7	35	32
7	20	18	2951	4.6	86	97.8	1.9	2.5	36	33
8	20	18	2949	4.6	83	97.7	1.9	2.6	37	33
9	13	13	2767	5.1	80	98.4	2.2	3.1	34	32
10	13	13	2557	6.1	76	98.5	2.5	3.7	31	32
11	15	14	2702	5.5	78	98.3	2.4	3.5	32	31
12	14	14	2462	5.7	79	98.4	2.3	3.4	27	26
13	13	13	2331	5.4	81	98.4	2.3	3.4	24	23
14	9	9	2026	6.0	79	99.0	2.3	3.4	21	21
15	7	7	1853	6.1	77	99.1	2.3	3.4	25	25
16	8	8	1807	5.8	78	99.0	2.2	3.3	33	32
17	13	13	1839	5.9	77	98.5	2.2	3.4	27	27
18	14	14	1896	5.8	76	98.4	2.1	3.3	27	27
19	16	15	2001	5.4	78	98.1	2.0	2.9	23	22
20	19	18	2049	4.9	77	97.8	2.1	2.9	27	26
21	10	9	1911	5.4	77	98.9	2.1	3.2	28	27
22	11	11	1891	4.9	81	98.6	2.7	4.3	31	29
23	11	10	1952	5.3	83	98.7	2.1	2.9	31	30
24	11	10	1916	5.4	83	98.7	2.0	2.9	28	27
25	13	12	2047	5.0	85	98.5	2.2	3.1	29	27
26	14	13	1952	5.1	81	98.4	2.4	3.3	27	26
27	10	10	1873	5.8	77	98.8	2.5	3.6	29	29
28	13	13	1812	6.2	73	98.4	2.8	4.3	28	28
29	12	12	1751	6.3	76	98.6	2.6	4.2	22	22
30	12	12	1935	5.9	77	98.6	1.4	2.0	29	29
31	13	12	2048	5.2	80	98.5	1.2	1.7	27	26
最大值	21	19	2951	6.4	86	99.2	2.8	4.3	37	33
最小值	7	7	1751	4.6	73	97.6	1.2	1.7	21	21
平均	13	12	2182	5.5	79	98.5	2.2	3.2	28	27

制表人：李中坚

审核人：吴兴远

企业负责人：卢连成

# 深圳妈湾电力有限公司2016年8月#3机组烟气数据

浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#3机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	22	20	2048	4.6	79	98.1	3.1	2.9	19	17
2	7	6	1929	4.9	79	99.1	2.9	3.1	19	18
3	9	9	1958	4.9	79	98.9	2.9	2.8	21	20
4	8	7	1932	5.4	76	98.9	2.8	2.8	23	22
5	13	12	1756	4.7	73	98.6	3.0	2.8	26	24
6	23	21	1956	4.1	82	98.0	3.2	2.8	29	26
7	20	17	1958	4.1	83	98.3	3.3	2.9	32	28
8	16	14	1998	4.3	81	98.4	3.1	2.7	29	26
9	16	14	1988	4.6	80	98.4	3.1	2.8	27	25
10	9	9	1912	6.2	74	99.0	2.8	2.9	26	26
11	16	15	1954	5.0	78	98.4	2.9	2.8	26	25
12	12	12	1979	5.6	76	98.7	2.9	2.9	26	25
13	12	11	1926	5.3	77	98.6	3.0	2.9	27	26
14	10	10	1850	6.2	78	98.9	2.9	3.0	32	32
15	9	9	1885	6.3	75	98.9	2.9	3.0	28	29
16	11	11	1928	5.6	75	98.7	2.9	2.8	26	26
17	14	13	1919	5.6	75	98.6	3.0	2.9	19	18
18	16	14	1917	5.2	76	98.4	3.0	3.0	23	22
19	18	16	1927	4.9	78	98.2	3.2	3.0	32	29
20	19	17	1956	4.3	80	98.1	3.1	2.8	36	32
21	12	12	1944	5.4	76	98.5	2.9	2.8	24	23
22	12	11	1964	4.2	79	98.4	3.0	2.7	33	29
23	12	11	1954	4.6	80	98.4	3.2	2.9	36	33
24	12	11	1949	4.7	81	98.4	3.0	2.8	30	28
25	16	14	1922	4.3	82	98.0	3.1	2.8	28	25
26	16	14	1958	4.5	81	98.2	3.2	2.9	30	28
27	15	13	1956	4.9	78	98.4	3.4	3.3	28	26
28	9	9	1929	6.1	74	98.9	3.1	3.2	25	25
29	9	9	1910	6.0	75	98.9	3.2	3.3	23	23
30	18	16	1937	4.8	78	98.3	3.3	3.2	26	24
31	17	15	1949	4.4	79	98.2	3.1	2.9	24	22
最大值	23	21	2048	6.3	83	99.1	3.4	3.3	36	33
最小值	7	6	1756	4.1	73	98.0	2.8	2.7	19	17
平均	14	13	1937	5.0	78	98.5	3.0	2.9	27	25

制表人：李中坚

审核人：吴兴远

企业负责人：卢连成



## 深圳妈湾电力有限公司2016年8月#4机组烟气数据

浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#4机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	17	16	1722	5.4	89	98.4	3.1	2.9	12	11
2	5	6	2306	7.7	88	99.5	2.9	3.1	15	17
3	8	8	2307	6.1	87	99.2	2.9	2.8	14	14
4	5	5	2239	6.2	84	99.6	2.8	2.8	13	13
5	10	10	2236	6.0	87	98.9	3.0	2.8	13	13
6	18	16	2247	4.6	91	97.9	3.2	2.8	16	15
7	26	23	2258	4.3	92	97.1	3.3	2.9	18	16
8	18	16	2244	4.2	91	98.2	3.1	2.7	16	14
9	17	16	2248	4.8	90	98.4	3.1	2.8	16	15
10	5	5	2193	7.0	82	99.5	2.8	2.9	15	16
11	10	10	2221	5.9	86	99.1	2.9	2.8	14	14
12	8	8	2217	6.1	85	99.2	2.9	2.9	13	13
13	11	10	2230	5.5	88	99.0	3.0	2.9	15	15
14	6	6	2181	7.0	85	99.4	2.9	3.0	13	14
15	6	6	2056	6.6	81	99.4	2.9	3.0	14	15
16	9	9	1996	6.1	85	99.1	2.9	2.8	13	14
17	11	11	2001	6.2	86	99.0	3.0	2.9	13	14
18	11	11	2027	6.2	86	98.9	3.0	3.0	17	18
19	10	9	2053	5.7	86	99.0	3.2	3.0	15	15
20	15	13	2057	5.1	87	98.2	3.1	2.8	15	14
21	6	6	2033	6.3	81	99.2	2.9	2.8	12	12
22	4	4	2065	4.7	89	99.5	3.0	2.7	15	13
23	5	4	2045	5.4	89	99.4	3.2	2.9	16	15
24	6	6	2044	5.2	91	99.2	3.0	2.8	16	15
25	7	7	2060	4.8	91	99.1	3.1	2.8	15	14
26	12	11	2064	4.9	89	98.5	3.2	2.9	14	13
27	13	12	2044	5.7	86	98.4	3.4	3.3	14	14
28	5	5	2009	7.2	81	99.4	3.1	3.2	12	13
29	5	5	2008	7.5	81	99.4	3.2	3.3	13	15
30	12	12	2045	6.5	84	98.5	3.3	3.2	15	15
31	11	10	2060	5.3	87	98.7	3.1	2.9	13	13
最大值	26	23	2307	7.7	92	99.6	3.4	3.3	18	18
最小值	4	4	1722	4.2	81	97.1	2.8	2.7	12	11
平均	10	9	2113	5.8	86	98.9	3.0	2.9	14	14

制表人：李中坚

审核人：吴兴远

企业负责人：卢连成

# 深圳妈湾电力有限公司2016年8月#5机组烟气数据



浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#5机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	8月1日9: 44机组启动运行									
2	8	9	2517	6.8	84	98.9	1.8	1.8	23	25
3	11	11	2587	6.4	85	98.8	1.8	1.8	26	27
4	7	7	2583	6.4	85	99.1	2.0	2.0	31	32
5	10	10	2597	6.5	85	98.8	1.7	1.8	26	27
6	8月6日19: 37机组停运, 8月8日19:10机组启动运行									
7										
8										
9	11	11	2618	6.2	85	98.7	1.8	1.7	26	27
10	5	6	2550	6.7	84	99.3	2.0	2.2	26	27
11	11	11	2601	6.4	85	98.8	2.2	2.2	26	27
12	7	7	2578	6.4	85	99.1	2.0	2.1	26	27
13	6	6	2492	5.5	85	99.1	2.1	2.2	27	26
14	4	4	2434	6.2	85	99.3	1.8	2.0	26	26
15	4	4	2070	6.5	79	99.4	1.9	2.0	26	26
16	5	5	1808	6.1	75	99.3	2.1	2.2	26	26
17	10	9	1867	5.8	77	98.9	2.2	2.3	27	26
18	13	12	1860	5.6	77	98.6	2.0	2.1	24	24
19	16	15	1900	5.8	78	98.3	2.2	2.2	22	21
20	21	19	1957	4.7	79	97.9	2.1	2.1	23	21
21	8	8	1870	5.8	76	99.0	1.6	1.7	22	21
22	8	7	1970	4.2	79	98.8	1.8	1.7	24	21
23	8	7	1931	4.9	80	98.9	2.1	2.1	23	21
24	8	8	1958	4.6	81	98.8	2.3	2.3	24	22
25	8	7	1973	4.3	82	98.9	2.5	2.4	24	22
26	6	5	1927	4.2	80	99.0	2.3	2.2	24	22
27	8	7	1900	5.4	79	99.0	2.6	2.6	22	22
28	5	5	1817	6.8	76	99.3	2.2	2.4	20	22
29	6	6	1810	6.6	77	99.2	2.2	2.4	21	21
30	14	12	1887	5.4	80	98.4	2.8	2.9	22	21
31	13	12	1925	4.2	80	98.5	3.0	2.9	24	21
最大值	21	19	2618	6.8	85	99.4	3.0	2.9	31	32
最小值	4	4	1808	4.2	75	97.9	1.6	1.7	20	21
平均	9	8	2148	5.7	81	98.9	2.1	2.2	24	24

制表人: 李中坚

审核人: 吴兴远

企业负责人: 卢连成

# 深圳妈湾电力有限公司2016年8月#6机组烟气数据



浓度单位 (mg/Nm<sup>3</sup>)      烟气量单位 万立方米/天

日期	#6机组脱硫系统出口									
	二氧化硫		烟气量	氧量%	温度℃	脱硫效率%	颗粒物		氮氧化物	
	标态	折算					标态	折算	标态	折算
1	24	23	2317	5.4	82	97.5	2.3	2.7	18	18
2	10	9	2233	5.6	85	98.9	1.8	1.8	21	21
3	14	13	2311	5.4	84	98.5	1.8	1.8	21	20
4	11	11	2334	5.3	81	98.6	2.0	2.0	16	15
5	15	14	2370	5.3	82	98.3	1.7	1.8	21	20
6	18	18	2494	5.2	85	97.8	2.0	2.2	20	19
7	12	11	2542	5.2	85	98.2	1.9	2.9	22	21
8	17	16	2523	5.2	84	97.8	1.7	2.3	23	22
9	14	13	2423	5.2	81	98.3	1.8	1.7	21	20
10	10	9	2320	5.4	75	98.7	2.0	2.2	25	24
11	12	12	2398	5.3	80	98.5	2.2	2.2	21	20
12	11	11	2286	5.3	79	98.6	2.0	2.1	19	18
13	10	9	2261	5.4	81	98.4	2.1	2.2	19	18
14	9	8	2156	5.4	78	98.3	1.8	2.0	17	16
15	9	8	2002	5.5	77	98.4	1.9	2.0	17	16
16	10	9	1913	5.7	79	98.7	2.1	2.2	24	24
17	11	11	1953	5.6	80	98.6	2.2	2.3	21	20
18	14	13	1985	5.5	81	98.5	2.0	2.1	26	25
19	17	15	2028	5.1	80	98.2	2.2	2.2	24	23
20	16	15	2087	4.8	81	98.2	2.1	2.1	28	25
21	10	10	1981	5.2	78	98.6	1.6	1.7	23	22
22	10	9	2118	4.5	82	98.3	1.8	1.7	24	21
23	10	9	2086	5.0	83	98.3	2.1	2.1	25	24
24	10	9	2049	5.0	82	98.4	2.3	2.3	22	20
25	10	9	2111	4.6	84	98.3	2.5	2.4	23	21
26	9	9	2069	4.8	82	98.2	2.3	2.2	23	21
27	10	9	1999	5.1	79	98.5	2.6	2.6	20	19
28	9	9	1909	5.8	79	98.1	2.2	2.4	23	23
29	8	9	1905	6.3	78	98.0	2.2	2.4	23	24
30	10	10	2013	5.6	81	97.9	2.8	2.9	22	22
31	11	10	2067	4.9	83	98.2	3.0	2.9	23	21
最大值	24	23	2542	6.3	85	98.9	3.0	2.9	28	25
最小值	8	8	1905	4.5	75	97.5	1.6	1.7	16	15
平均	12	11	2169	5.3	81	98.3	2.1	2.2	22	21

制表人：李中坚

审核人：吴兴远

企业负责人：卢连成